



TECHNICAL GUIDELINE

Building Safety Division

- ☒ TECHNICAL GUIDELINE
- ☐ CODE INTERPRETATION
- ☐ CODE MODIFICATION

Issue Date:	8/31/26
Building Code Sections:	N 300.4 (C) Damaged Conductors and wiring Methods
Developed by:	Building Safety Division
Approved by:	Brian Hickman (Building Safety Official)
References:	NFPA 70 – National Electrical Code 2026

The purpose of this Technical Guideline is to eliminate any ambiguity and ensure that wiring compromised by environmental or physical conditions is not simply left in place or re-energized without evaluation.

Guideline:

N 300.4 (C) Conductors and wiring methods that are no longer suitable for use due to damage, such as overheating, fire damage, corrosive influences, or water, shall be replaced.

NOTICE: This Technical Policy will become Effective on 9/1/2026