

## HOW TO APPLY

# Backflow Requirements



### When

903.3.5 Water Supplies. The potable water supply shall be protected against backflow in accordance with the requirements of this section and the International Plumbing Code.

### Where

903.4.1 Monitoring. In occupancies required to be equipped with a fire alarm system, the backflow prevention valves shall be electrically supervised by a tamper switch installed in accordance with NFPA 72 and separately annunciated.

### How

01



903.4.1 Monitoring. Backflow prevention device test valves located in limited area sprinkler system supply piping shall be locked in the open position.

02



903.4 Sprinkler system supervision and alarms. Valves controlling the water supply for automatic sprinkler systems on all sprinkler systems shall be electrically supervised by a listed fire alarm control unit.

03



903.4.1 Monitoring. Underground Key or Hub Valves in roadway boxes provided by the municipality or public utility are not required to be monitored

04



903.4.1 Monitoring. In occupancies required to be equipped with a fire alarm system, the backflow prevention valves shall be electrically supervised by a tamper switch installed in accordance with NFPA 72 and separately annunciated.

Learn more contact Fire Plan Review



Glendale Fire Department