

KEY BOXES

IFC 2018 Section 506

Access to or within a structure or an area is restricted because of secured openings or where immediate access is necessary for life-saving or fire-fighting purposes. The key box shall be of an approved type listed in accordance with UL 1037

Height - 60inches to 72inches

Located within 5ft on door swing side or approved by Fire Code Official



1




Fire Access Vehicle Gates

All gates identified for fire access

Gates or similar barriers


2



Doors

Main Entry, Fire Riser Room, Fire Pump Room, Fire Command, Exterior Electrical Room, Exterior Mechanical Room

3



Perimeter Property Door Gates

Main entry and locations as required by the fire code official.

Gates or similar barriers

4



Fire Access Doors

All doors require key boxes

5



Stairs

All stairs to include access to roof

6



Elevators

506.1.2
Labeled Fire Department Use Only - Elevator Keys
At each Elevator bank at the lobby nearest to lowest fire access level
Mounted 5ft 6in to right side of elevator bank
Contents limited to elevator keys, tools and information pertinent to planning and access

