

Address Identification

New and existing buildings shall have *approved* illuminated address numbers, building numbers or *approved* illuminated building identification placed in a position from left to right that is plainly legible and visible from the street or road fronting the property with a maximum height of 20ft. These numbers shall contrast with their background. Address numbers shall be Arabic numerals or alphabet letters. Multiple Commercial buildings under one address those buildings not labeled with address number shall be a minimum of 12" (304.8mm) high. Commercial units within a building shall be a minimum of 6 inches (152 mm) high to include the rear of units. Exterior Residential Individual unit or suite numbers shall be a minimum of 4 inches (102 mm) high. Interior Residential Individual unit or suite numbers shall be a minimum of 2 inches (609.6mm) high. One and two-family dwelling shall be a minimum of 4 inches (102 mm) high. Where access is by means of a private road and the building cannot be viewed from the public way, a monument, or other sign or means shall be used to identify the structure. Address numbers shall be maintained. Address and building numbers for commercial properties shall be as follows:

1. 100ft or less setback from addressed street curb – 8"
2. 101ft – 150ft setback from addressed street curb – 10"
3. 151ft – 200ft setback from addressed street curb – 12"
4. 201ft or greater setback from addressed street curb – Permanent sign that is not more than 50ft from the street curb.

Graphic Directories

Approved illuminated, all weather graphic directories shall be provided at all driveway entrances for every multiple family dwelling development, mobile home park and commercial development as required by the Fire Code Official. Such directories shall conform to the Glendale Fire Department standard for graphic directories.

1. Communities containing 12 or fewer building require a minimum 3 by 3 feet site directory
2. Communities containing 13 to 30 buildings require a minimum 4 by 4 feet site directory
3. Communities containing 31 or more buildings require a minimum 5 by 5 feet site directory