

CITY OF GLENDALE

LIQUIFIED PETROLEUM GAS REQUIREMENTS

1. A Fire Department permit is not required to install or maintain portable containers of less than 125 gallons aggregate water capacity.
 - * Any tank exceeding 125 gallon aggregate water capacity requires review by the Fire Department and has a review time of 3 working days.
 2. Tanks shall be accessible for inspection. (Current International Plumbing Code).
 3. All exposed gas piping shall be kept at least 6 inches above-grade and secured.
 4. All tanks require a shut-off control valve.
 5. Distances:
 - 10 feet from any electrical unless electrical is explosion proof
 - 10 feet from any source of open flame or ignition
 - 5 feet from any opening into the home or structure
 - 5 feet from the property line. Exception: Block fence walls may act as a vapor barrier.
 6. Anchor tanks with a chain or strap.
 7. Tanks must be installed on a non-combustible base (2-inch concrete) with 30 inches of working space and platform. (Current International Fire Code)
- * We do recognize manufacture installation requirements for appliances.

PERMIT FEE - \$122.88

Note: Liquified petroleum gas shall not serve any appliance located in a pit or basement where gas that is heavier than air might collect to form a flammable mixture.

